

# FIRE CERTIFICATION

HEAT SHRINK WRAP FILM

## STATEMENT OF PERFORMANCE

SUBJECT: Heat Shrink Wrap membranes

IN REFERENCE TO: Compliance with NFPA 701 Method 2 (large scale) flame propagation test

DATE: June 2, 2009

Heat Shrink Polyethylene FR is a polyethylene based formulation with fire retardant additives. This film is opaque white.



Tevan Riedel  
CEO of Americover, Inc

# FIRE CERTIFICATION

HEAT SHRINK WRAP FILM

SPECIMEN NO.	INITIAL WIGHT (G)	FINAL WEIGHT (G)	PERCENT WEIGHT LOSS	PERCENT WEIGHT LOSS	TIME OF FLAMING PIECES ON FLOOR (SECONDS)
1	12.6	9.8	2.8	22.2	0
2	12.6	10.0	2.6	20.6	0
3	12.6	11.2	1.4	11.1	0
4	12.8	11.5	1.3	10.2	0
5	12.9	10.3	2.6	20.2	0
6	12.4	9.1	3.3	26.6	0
7	12.6	9.3	3.3	26.2	0
8	12.5	8.7	3.8	30.4	0
9	12.4	9.2	3.2	25.8	0
10	12.7	10.3	2.4	18.9	0
21.2 Average Percent Weight Loss					
6.6 Standard Deviation					
0 Average Time of Flaming of Pieces on Floor (seconds)					

The information provided herein is based upon data believed to be reliable. All testing is performed in accordance with ASTM standards and procedures. All values are typical and nominal and do not represent either minimum or maximum performance of the product. Although the information is accurate to the best of our knowledge and belief, no representation of warranty or guarantee is made as to the suitability or completeness of such information. Likewise, no representation of warranty or guarantee, express or implied, or merchantability, fitness or otherwise, is made as to product application for a particular use.



Scan for our mobile app

